

# POLSKIE CENTRUM BADAŃ I CERTYFIKACJI S.A.

02-699 Warszawa, ul. Kłobucka 23A



## CERTIFICATE OF CONFORMITY No CE/13/7/10/BE

Product certification system-1a (ISO/IEC Guide 67).

Name and address of the certificate holder:

**FERRO S.A.**  
ul. Przemysłowa 7, 32-050 Skawina, Poland.

Name and address of the manufacturer:

**FERRO S.A.**  
ul. Przemysłowa 7, 32-050 Skawina, Poland.

Product:

Circulation pump

Model/type Ref.:

1) 25-40-180; 2) 25-60-180

Trademark:

WEBERMAN

Ratings:

230V ~; 50-60Hz; 65W(1); 100W(2); class I

The product complies with the safety requirements set in the following standards:

EN 60335-1:2002+A11:2004+A1:2004+A12:2006+A2:2006+A13:2008;  
EN 60335-2-51:2003+A1:2008; EN 50366:2003+A1:2006;  
EN 55014-1:2006+A1:2009; EN 55014-2:1997+A1:2001+A2:2008;  
EN 61000-3-2:2006+A1:2009+A2:2009; EN 61000-3-3:2008

As shown in the test report carried out by:

PCBC S.A.

Ref. No. and date of the test report:

BE/137/2008 – 1/U/2010 of 26.01.2010;  
BE/138/2008 – 1/U/2010 of 26.01.2010;  
BE/141/2008 of 27.05.2008; BE/142/2008 of 26.05.2008

The test results confirm that the tested sample of product fulfils the requirements of harmonized standards against directive LVD 2006/95/EC and analysis of the product construction confirms the fulfillment of the essential requirements included in the directive EMC 2004/108/EC. In case the rest of the appropriate requirements of directives is fulfilled, especially after establishing the technical documentation file as well issuing the EC Declaration of Conformity, the manufacturer or his EU representative can affix the CE marking to product, on his own responsibility.

DIRECTOR for TESTING and CERTIFICATION

Tadeusz Glazer

Warsaw, 29.04.2011

Electrical Product Certification Department